
CERTIFICATE HEADER

Certificate Name: LEKTEK

Certificate Type: LEKTEK

Prepared by:

A Long

On Behalf of: *(Name & Address)*

Lektek Ltd
Kestrel Court
Waterwells Drive
Waterwells Business Park
Gloucester
GL2 2AT

Prepared For: **Client:** *(Name & Address)*

Location: *(Name & Address)*

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

Notes: *(If Applicable)*

**APPLIANCE TESTING
CERTIFICATE
PASSED**

CLIENT AND LOCATION DETAILS

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

Asset ID	Description	Room	Test Date	Visual	Cont 1	Ins.	Oper.	Leak.	Repair	Status
ML001	EXT 4WAY	STORES	13/07/2018	Pass	0.12	>99.90			0	P
ML002	EXT 4WAY	STORES	13/07/2018	Pass	0.05	>99.90			0	P
ML003	EXT 4WAY	STORES	13/07/2018	Pass	0.10	>99.90			0	P
ML004	EXT 6WAY	STORES	13/07/2018	Pass	0.06	>99.90			0	P
ML005	EXT 2WAY	STORES	13/07/2018	Pass	0.19	>99.90			0	P
ML006	EXT 1WAY	STORES	13/07/2018	Pass	0.19	>99.90			0	P
ML007	EXT 4WAY	STORES	13/07/2018	Pass	0.12	>99.90			0	P
ML008	EXT 4WAY	STORES	13/07/2018	Pass	0.10	>99.90			0	P
ML009	EXT 1WAY	STORES	13/07/2018	Pass	0.19	>99.90			0	P
ML010	EXT 4WAY	STORES	13/07/2018	Pass	0.10	>99.90			0	P
ML011	IEC LEAD	STORES	13/07/2018	Pass	0.12	>99.90			0	P
ML012	IEC LEAD	STORES	13/07/2018	Pass	0.07	>99.90			0	P
ML013	IEC LEAD	STORES	13/07/2018	Pass	0.07	>99.90			0	P
ML014	IEC LEAD	STORES	13/07/2018	Pass	0.07	>99.90			0	P
ML015	IEC LEAD	STORES	13/07/2018	Pass	0.09	>99.90			0	P
ML016	IEC LEAD	STORES	13/07/2018	Pass	0.09	>99.90			0	P
ML017	IEC LEAD	STORES	13/07/2018	Pass	0.11	>99.90			0	P
ML018	IEC LEAD	STORES	13/07/2018	Pass	0.12	>99.90			0	P
ML019	IEC LEAD	STORES	13/07/2018	Pass	0.08	>99.90			0	P
ML020	IEC LEAD	STORES	13/07/2018	Pass	0.11	>99.90			0	P
ML021	IEC LEAD	STORES	13/07/2018	Pass	0.09	>99.90			0	P
ML022	AC ADAPTOR	STORES	13/07/2018	Pass		>99.90			0	P
ML023	AC ADAPTOR	STORES	13/07/2018	Pass		>99.90			0	P
ML024	PSU LIGHT	STORES	13/07/2018	Pass		>99.90			0	P
ML025	PSU LIGHT	STORES	13/07/2018	Pass		>99.90			0	P
ML026	PSU LIGHT	STORES	13/07/2018	Pass		>99.90			0	P
ML027	IEC LEAD	STORES	13/07/2018	Pass	0.05	>99.90			0	P
ML028	IEC LEAD	STORES	13/07/2018	Pass	0.09	>99.90			0	P
ML029	IEC LEAD	STORES	13/07/2018	Pass	0.14	>99.90			0	P
ML030	IEC LEAD	STORES	13/07/2018	Pass	0.06	>99.90			0	P
ML031	EXT 4WAY	STORES	13/07/2018	Pass	0.11	>99.90			0	P
ML032	EXT 4WAY	STORES	13/07/2018	Pass	0.11	>99.90			0	P
ML033	LIGHT	STORES	13/07/2018	Pass	0.08	>99.90			0	P
ML034	SPOTLIGHT	STORES	13/07/2018	Pass	0.11	>99.90			0	P
ML035	SPOTLIGHT	STORES	13/07/2018	Pass	0.17	>99.90			0	P
ML036	LED LIGHTING	STORES	13/07/2018	Pass	0.11	>99.90			0	P
ML037	LED LIGHTING	STORES	13/07/2018	Pass	0.09	>99.90			0	P
ML038	EXT 6WAY	STORES	13/07/2018	Pass	0.09	>99.90			0	P

**APPLIANCE TESTING
CERTIFICATE
PASSED**

CLIENT AND LOCATION DETAILS

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

Asset ID	Description	Room	Test Date	Visual	Cont 1	Ins.	Oper.	Leak.	Repair	Status
ML039	AC ADAPTOR	STORES	13/07/2018	Pass		>99.90			0	P
ML040	AC ADAPTOR	STORES	13/07/2018	Pass		>99.90			0	P
ML041	IEC LEAD	STORES	13/07/2018	Pass	0.06	>99.90			0	P
ML042	AC ADAPTOR	STORES	13/07/2018	Pass		>99.90			0	P
ML043	MIXER	STORES	13/07/2018	Pass	0.08	>99.90			0	P
ML044	AMPLIFIER	STORES	13/07/2018	Pass	0.10	>99.90			0	P
ML045	AMPLIFIER	STORES	13/07/2018	Pass	0.10	>99.90			0	P
ML046	AMPLIFIER	STORES	13/07/2018	Pass	0.09	>99.90			0	P
ML047	AMPLIFIER	STORES	13/07/2018	Pass	0.09	>99.90			0	P
ML048	AMPLIFIER	STORES	13/07/2018	Pass	0.09	>99.90			0	P
ML049	IEC LEAD	STORES	13/07/2018	Pass	0.07	>99.90			0	P
ML050	PSU LAPTOP	STORES	13/07/2018	Pass		>99.90			0	P